


Värmerapport

2010-05-03 07:57

Norrtullsgatan 12B Fj0140069156
 Driftansvarig : Norrtullsgatan 12 B
 Riddarsporren 18-20

Värme Norrtullsgatan 12B Fj0140069156

kWh/m²



Period	Graddagar		Förbrukning				Jämförelsetal			Avvikelse		
	Verk.	Norm.	dT °C	Värme MWh	Total MWh	Normal MWh	2010 kWh/m ²	2009 kWh/m ²	2008 kWh/m ²	Mål kWh/m ²	2009 %	Mål %
	30464											
Jan	771	600	53.9	151.3	151.3	123.4	15.1	24.9	23.5	18.0	-39.5	-16.3
Feb	635	552	54.6	129.6	129.6	115.7	14.2	20.9	20.3	16.5	-32.1	-14.3
Mar	550	515	49.0	106.8	106.8	101.5	12.4	19.7	20.3	16.0	-36.9	-22.4
Apr	---	---	---	---	---	---	---	11.1	15.1	---	---	---
Maj	---	---	---	---	---	---	---	6.3	8.8	---	---	---
Jun	---	---	---	---	---	---	---	2.6	3.3	---	---	---
Jul	---	---	---	---	---	---	---	2.0	2.7	---	---	---
Aug	---	---	---	---	---	---	---	2.2	3.3	---	---	---
Sep	---	---	---	---	---	---	---	3.2	8.2	---	---	---
Okt	---	---	---	---	---	---	---	8.0	12.1	---	---	---
Nov	---	---	---	---	---	---	---	11.6	18.8	---	---	---
Dec	---	---	---	---	---	---	---	13.6	22.9	---	---	---
2010	1956	1667	52.6	387.7	387.7	340.6	41.7	126.0	159.1	50.5	---	-17.6
	30464											
2010 (prog)	---	---	---	729.2	729.2	655.5	80.2	---	---	130.0	-49.6	-38.3
2009	3348	3620	35.6	981.7	981.7	1029.6	126.0	---	---	130.0	-20.9	-3.1
2008	3046	3620	31.1	1161.0	1161.0	1300.9	159.1	---	---	130.0	---	--